

**Final Hearing Report
Orange Village Centre
Drainage Petition per Ohio Revised Code Sec. 6131
July 7, 2023**

This report has been prepared for the final hearing on a drainage petition filed by Orange Village Centre on May 4, 2018. The petition was signed by 6 individuals with an interest in the single parcel comprising the project.

The general location and course of the requested improvements are quoted from the petition as follows:

In Delaware County, Orange Twp. in Orange Village Centre recorded covenants, easements, restrictions, assessments and assessments for liens and generally following the existing course and terrain of the improvement as shown on exhibits A and D.

The following is the nature of the work petitioned:

To repair, replace or alter the existing improvements as required and to maintain these improvements per the engineer plans and attached exhibit A and D.

Petition Process

This petition has been submitted according to section 6131 of the Ohio Revised Code, which authorizes the County Commissioners to act on behalf of benefited property owners to make drainage improvements as requested by the petitioners. Should the commissioners find in favor of the petition, the existing storm water drainage system will be placed on the Delaware County Drainage Maintenance program in perpetuity per section 6137 of The Ohio Revised Code. The special maintenance assessments that follow this action would appear on each property's tax duplicate semi-annually. The Cost of maintenance would average 2% to 5% annually of the current value of construction costs, and is divided equally among the benefiting properties.

The decision to approve a petition project is a 3-step process. First, a viewing of the proposed drainage petition is conducted for the Commissioners to familiarize themselves with the site. The commissioners conducted the viewing for this project on August 20, 2018. Next, a preliminary hearing is held to consider the initial feasibility and benefit of the request. This hearing was held October 25, 2018. At this first hearing, the Commissioners found in favor of the petition. They requested the Delaware County Engineer and the Delaware Soil and Water Conservation District to proceed with the detailed inspection and assessment of the storm water system, the development of engineering plans and specifications, and the development

of the schedule of assessments. It is this information that is before the Board of Commissioners at this second and final hearing.

Existing Conditions

The Delaware Soil and Water Conservation District performed an inventory and evaluation of the existing storm water drainage system. The system generally appears to have been installed and is functioning per the original engineering plans. - Several areas will require minor improvement or repairs once the project is accepted onto the County Drainage Maintenance Program.

- A new culvert will need to be installed under the bike/walking path downstream of the pond outlet.
- Storm lines will require jet cleaning due to the accumulation of grit and debris.

This work is estimated to cost \$20,000. This will necessitate an initial 5% maintenance assessment collection.

The existing retention pond will be maintained for storm water functionality only. Aesthetic maintenance will remain the responsibility of Orange Village Centre.

Maintenance and Construction Cost Estimate

The annual maintenance assessment for each of the properties would be estimated as follows:

Estimated current value of original improvement:	\$ 225,443.39
--	---------------

The annual maintenance assessment is calculated by multiplying the current value of the improvement by the percentage to be collected. For the initial 5% collection, this produces a maintenance assessment of \$11,272.17.

Recommendations

Based on all of the information gathered for this petition request, I believe the project should proceed. It is my opinion that the benefits of the proposed petition exceed the estimated maintenance costs and would be conducive to the public welfare.

Should the Board of Commissioners choose to move forward with this project and affirm the order to proceed, I would request a separate resolution that Orange Village Centre be accepted into the Delaware County Drainage Maintenance Program and that the schedule of assessments be approved and confirmed as submitted. I would also request that a 5% collection rate be certified to the Delaware County Auditor for special assessments for Orange Village Centre to begin in January 2025.

If the Board of Commissioners chooses to dismiss the petition, I would recommend a resolution reflecting that decision and that the costs for the proceedings, including the costs incurred by the Board of Commissioners, the County Engineer, and the Delaware Soil and Water Conservation District in making the reports and schedules be distributed to the benefiting property owners in the same ratio as determined in the final estimated assessments presented at this hearing.

Prepared by,



Bret Bacon
Deputy Administrator
Delaware Soil and Water
Conservation District

Approved by,



Chris Bauserman P.E., P.S.
Delaware County Engineer